



PERIDOT CORPORATION

1072 Serpentine Lane, Suite E
Pleasanton, CA 94566

This certifies that your Cleanroom was tested in accordance with industry standards. Equipment used for the certification was an APC Laser Particle Counter (calibration date 04-17-08 due 04-17-09). Cleanroom meets and conforms to Federal Standards 209-E, which is less than 10,000 particles per cubic foot at 0.5 microns and above in size.

Cleanroom meets Class 10,000 requirements
February 4, 2009

FLOWSTAR, INC.
6800 Silacci Way
Gilroy, CA 95020


Mike Bennett